

Water Testing Results - Astoria High School

Action Level is 15 parts per billion (ppb)

Fixture Location/Description	Fixture ID #	Test Date	Test Result	Corrective Action Taken
Sports Hall Faucet	AHS-001	6/14/2016	17.5 ppb	Retest with updated protocol
Sports Hall Faucet	AHS-001	7/14/2016	51.8 ppb	Plumbing and faucet replaced
Sports Hall Faucet	AHS-001	10/14/2016	ND	
Classroom Hall 2nd Floor Faucet	AHS-002	7/14/2016	13.9 ppb	Bubbler replaced
Classroom Hall 2nd Floor Faucet	AHS-002	10/11/2016	ND	
Classroom Hall 1st Floor Faucet	AHS-003	6/14/2016	83.6 ppb	Retest with updated protocol
Classroom Hall 1st Floor Faucet	AHS-003	7/14/2016	32.7 ppb	Feed lines replaced
Classroom Hall 1st Floor Faucet	AHS-003	10/11/2016	ND	
Auditorium Hall Faucet	AHS-004	7/14/2016	24.8 ppb	Plumbing and faucet replaced
Auditorium Hall Faucet	AHS-004	10/11/2016	ND	
Kitchen Sink Cafeteria	AHS-005	6/14/2016	3.2	
Special Ed Room	AHS-006	6/14/2016	ND	

ND = Non Detect - Lead level is below the set detection limits